

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1100755

Product: Switchboard enclosures

Type: MDS 6U, MDS 9U, MDS 12U, MDS 15U,
MVS 9U, MVS 12U, MVS 15U, MVS 17U,
MSS 15U, MSS 17U, MSS 22U, MSS 27U, MSS 32U,
MSS 37U, MSS 42U, MSS 45U, MSS 47U,
MNS 4U, MNS 6U, MNS 9U, MNS 12U,
MNS 15U, MNS 17U, MNS 18U

Rating: 230/400 V, IP 20, IK 06 (MSD, MSV)

Ordering firm: MICOS spol. s r.o.
Vápenice 17, 796 01 Prostějov, Czech Republic

Manufacturer: MICOS spol. s r.o.
Vápenice 17, 796 01 Prostějov, Czech Republic

Factories: MICOS spol. s r.o.
Průmyslová zóna B - Prostějov, část Háj 365, 798 12 Kralice na Hané, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 003858-01/01 of: 20.10.2010

A sample of the product was found to be in conformity with:
ČSN EN 60439-3:95+A1:97+A2:02, ČSN EN 62208:04, ČSN 35 7030:72, ČSN EN 60439-1:00 ed.2 +A1:04+1:08

The validity of the certificate is limited to: 31.10.2013

27.10.2010

Prague


Miroslav Sedláček
Certification and Inspection Manager

Stamp



003858-01