

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHÉCHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1080010

**Product:** Plastic Switchboards

**Type:** MRK 2, MRK 10, 20, MRS 10, 20, MRS 3p, MRS 200, 300MIS 1a, MIS 1b, MIS 2, MIS 3, MIS 200, 300, SIS 1, SIS 1d, SIS 2, SIS 3, SIS 200, 300

**Rating:** 400 V, IP 54, IP 30

**Ordering firm:** MICOS spol. s r.o.  
Vápenice 17, 796 01 Prostějov, Czech Republic

**Manufacturer:** MICOS spol. s r.o.  
Vápenice 17, 796 01 Prostějov, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 704719-01/01 of: 13.12.2007

**A sample of the product was found to be in conformity with:**  
ČSN EN 60439-3:95+A1:97+A2:02, ČSN 35 7030:72

**The validity of the certificate is limited to:** 31.12.2010

22.9.2008

Prague

Pavel Kudrna  
Certification and Inspection Manager



Stamp



704719-01